



# STEAM LINE SIZING:

## » WHY IT IS IMPORTANT AND HOW TO CORRECTLY SIZE

### HOW TO CORRECTLY SIZE

Selecting the correct size for a steam line is one of the most important items in a properly operating steam system. Steam lines are designed for 200 years of operation, and the plant should not experience premature failure with a properly designed and operated steam line.

One important factor to remember about steam system design is that a steam system must be viewed as a complete system rather than its component parts; therefore, all aspects need to be reviewed to ensure proper operation. For example, undersized steam lines will lead to steam starvation and steam pressure loss at the steam end user. This pressure loss is often mistakenly assumed to result from heat transfer problems or control valve issues.

Providing the correct steam pressure and steam quality to the end user is the goal of the steam distribution lines. Steam lines always will have a steam pressure drop with all the restrictions to steam flow, such as valves, elbows, pipe internal roughness, flow meters, expansion devices, and other items. The plant needs to determine the acceptable steam pressure drop for the steam distribution system and deliver the correct steam pressure to the end user.

When designing steam headers, branch lines, and condensate lines, there are general rules regarding velocities in the piping. Oversizing a steam or condensate line is never a problem except for the additional cost at installation, and it will add a very small additional energy loss through the insulation. However, the benefits of oversizing far outweigh the negatives of undersizing.

### UNDERSIZING STEAM LINE NEGATIVES

Undersizing steam lines will increase the steam velocities, which, in turn, will increase the noise (dBA level) and



Figure 1: Steam Line Profiling for Pressure Drops



Figure 2: Steam Distribution System

pressure drops in the steam system. Higher velocities of 10,000 fpm or more will present four additional problems in the system:

### Steam Quality

High velocities in the steam line will entrain the condensate that forms from thermal losses through the insulation. The end result will be lower steam quality. The design of the steam distribution system should provide at least steam quality of at least 98% to the end user.

### Higher Steam Line Pressure Drops

The steam line pressure drops will increase with higher steam line velocities.

### Premature Steam Line Component Failures

Poor steam quality in the steam line will cause erosion in the steam line elbows, flow meters, isolation valves, and other items.

### Water Hammer

In severe cases, the result could be water hammer in the system.

## WHAT ARE THE CORRECT VELOCITIES?

- Steam heating system velocities:  
6,000 feet per minute
- Process steam velocities:  
10,000 feet per minute
- Condensate piping velocities (two-phase flow/flash steam):  
4,500 feet per minute
- Condensate piping velocities (liquid only):  
420 feet per minute

## -sizing Steam Lines for Velocity

### Formula for velocity in steam piping:

$$\text{Velocity} = \frac{2.4 \times \text{flow} \times \text{specific volume}}{\text{cross-sectional area}}$$

- Flow = lbs. per hour
- Specific volume (typically at the end of the steam line) cubic ft. per lb.
- Cross-sectional area of the pipe

### Internal area in square inches

#### Example:

Steam Flow: 110,000 lbs.hr  
 Steam Pressure: 215 psig  
 10" Sch. 40 pipe: 78.9 (cross-sectional area)

$$\text{Line A} = \frac{2.4 \times 110,000 \times 2.002}{78.9 \text{ area}} = 6698 \text{ FPM}$$

## Calculating the Steam Line Pressure Drop

When calculating the pressure drop for steam lines of any length, it is not sufficient to depend upon calculations based on velocity alone. Velocity is only one part of the solution.

### Formula:

$$P_d = P_1 - P_2 = \frac{0.0484 f L G^2}{D^5 W}$$

- $P_d$  = Pressure drop in lbs. per square in.
- $P_1$  = Initial pressure in lbs. per square in. absolute
- $P_2$  = Final pressure in lbs. per square in. absolute
- $f$  = Friction factor
- $G$  = Lbs. of steam per minute
- $D$  = Internal diameter (inches)
- $L$  = Length of pipe

$$W = \frac{1}{V_s} = \text{weight of steam per cubic feet of pressure } P_1$$

## EXAMPLE

$P_1$  = 234 psia  
 Steam flow = 90,000 lbs. per hour  
 Pipe size = 10"  
 Pipe schedule = 40  
 Length = 1,000 ft.

**Step 1.**

$$W = \frac{1}{V_s} = \text{weight of steam per cubic feet of pressure P1}$$

$$V_1 = 1.960 \text{ ft.}^3/\text{lb.}, \quad W = \frac{1}{1.96} = 0.509 \text{ lbs./ft.}^3$$

$$\text{Pressure Drop} = \frac{(0.0484) (0.0053) (1,000) (90,000/60 \text{ steam flow mins.})^2}{(10.02)^5 (0.509 \text{ lbs. ft.}^3)}$$

$$\text{Pressure Drop} = 234 \text{ psig} - P_2 = \frac{577,170}{51,411}$$

$$\text{Pressure Drop} = 234 \text{ psia} - P_2 = 11.23$$

**$$P_2 = 222.8 \text{ psia}$$**

PROPERTIES OF PIPE

nominal pipe size outside diameter, in.	schedule number*			wall thickness, in.	inside diameter, in.	inside area, sq. in.	metal area, sq. in.	sq ft outside surface, per ft	sq ft inside surface, per ft	weight per ft, lbt	weight of water per ft, lb	moment of inertia, in. <sup>4</sup>	section modulus, in. <sup>3</sup>	radius gyration, in.
	a	b	c											
1V2 1.900	40	Std	408	0.145	1.610	2.036	0.799	0.497	0.421	2.718	0.882	0.310	0.326	0.623
	80	XS	SOS	0.200	1.500	1.767	1.068	0.497	0.393	3.631	0.765	0.391	0.412	0.605
	160	-	-	0.281	1.338	1.406	1.429	0.497	0.350	4.859	0.608	0.483	0.508	0.581
	-	XXS	-	0.400	1.100	0.950	1.885	0.497	0.288	6.408	0.412	0.568	0.598	0.549
	-	-	-	0.525	0.850	0.567	2.267	0.497	0.223	7.710	0.246	0.6140	0.6470	0.5200
-	-	-	0.650	0.600	0.283	2.551	0.497	0.157	8.678	0.123	0.6340	0.6670	0.4980	
2 2.375	-	-	58	0.065	2.245	3.96	0.472	0.622	0.588	1.604	1.716	0.315	0.2652	0.817
	-	-	108	0.109	2.157	3.65	0.776	0.622	0.565	2.638	1.582	0.499	0.420	0.802
	40	Std	408	0.154	2.067	3.36	1.075	0.622	0.541	3.653	1.455	0.666	0.561	0.787
	80	XS	BOS	0.218	1.939	2.953	1.477	0.622	0.508	5.022	1.280	0.868	0.731	0.766
	160	-	-	0.343	1.689	2.240	2.190	0.622	0.442	7.444	0.971	1.163	0.979	0.729
	-	XXS	-	0.436	1.503	1.774	2.656	0.622	0.393	9.029	0.769	1.312	1.104	0.703
	-	-	-	0.562	1.251	1.229	3.199	0.622	0.328	10.882	0.533	1.442	1.2140	0.6710
-	-	-	0.687	1.001	0.787	3.641	0.622	0.262	12.385	0.341	1.5130	1.2740	0.6440	
2Y2 2.875	-	-	58	0.083	2.709	5.76	0.728	0.753	0.709	2.475	2.499	0.710	0.494	0.988
	-	-	108	0.120	2.635	5.45	1.039	0.753	0.690	3.531	2.361	0.988	0.687	0.915
	40	Std	408	0.203	2.469	4.79	1.704	0.753	0.646	5.793	2.076	1.530	1.064	0.947
	80	XS	SOS	0.276	2.323	4.24	2.254	0.753	0.608	7.661	1.837	1.925	1.339	0.924
	160	-	-	0.375	2.125	3.55	2.945	0.753	0.556	10.01	1.535	2.353	1.637	0.894
	-	XXS	-	0.552	1.771	2.464	4.03	0.753	0.464	13.70	1.067	2.872	1.998	0.844
	-	-	-	0.675	1.525	1.826	4.663	0.753	0.399	15.860	0.792	3.0890	2.1490	0.8140
-	-	-	0.800	1.275	1.276	5.212	0.753	0.334	17.729	0.554	3.2250	2.2430	0.7860	
3 3.500	-	-	58	0.083	3.334	8.73	0.891	0.916	0.873	3.03	3.78	1.301	0.744	1.208
	-	-	108	0.120	3.260	8.35	1.274	0.916	0.853	4.33	3.61	1.822	1.041	1.196
	40	Std	408	0.216	3.068	7.39	2.228	0.916	0.803	7.58	3.20	3.02	1.724	1.164
	80	XS	SOS	0.300	2.900	6.61	3.02	0.916	0.759	10.25	2.864	3.90	2.226	1.136
	160	-	-	0.437	2.626	5.42	4.21	0.916	0.687	14.32	2.348	5.03	2.876	1.094
	-	XXS	-	0.600	2.300	4.15	5.47	0.916	0.602	18.58	1.801	5.99	3.43	1.047
	-	-	-	0.725	2.050	3.299	6.317	0.916	0.537	21.487	1.431	6.5010	3.7150	1.0140
-	-	-	0.850	1.800	2.543	7.073	0.916	0.471	24.057	1.103	6.8530	3.9160	0.9840	
3½ 4.000	-	-	58	0.083	3.834	11.55	1.021	1.047	1.004	3.47	5.01	1.960	0.980	1.385
	-	-	108	0.120	3.760	11.10	1.463	1.047	0.984	4.97	4.81	2.756	1.378	1.372
	40	Std	408	0.226	3.548	9.89	2.680	1.047	0.929	9.11	4.28	4.79	2.394	1.337
	80	XS	SOS	0.318	3.364	8.89	3.68	1.047	0.881	12.51	3.85	6.28	3.14	1.307
	-	XXS	-	0.636	2.728	5.845	6.721	1.047	0.716	22.850	2.530	9.8480	4.9240	1.2100
4 4.500	-	-	58	0.083	4.334	14.75	1.152	1.178	1.135	3.92	6.40	2.811	1.249	1.562
	-	-	108	0.120	4.260	14.25	1.651	1.178	1.115	5.61	6.17	3.96	1.762	1.549
	-	-	-	0.188	4.124	13.357	2.547	1.178	1.082	8.560	5.800	5.8500	2.6000	1.5250
	40	Std	408	0.237	4.026	12.73	3.17	1.178	1.054	10.79	5.51	7.23	3.21	1.510
	80	XS	SOS	0.337	3.826	11.50	4.41	1.178	1.002	14.98	4.98	9.61	4.27	1.477
	120	-	-	0.437	3.626	10.33	5.58	1.178	0.949	18.96	4.48	11.65	5.18	1.445
	-	-	-	0.500	3.500	9.621	6.283	1.178	0.916	21.360	4.160	12.7710	5.6760	1.4250
	160	-	-	0.531	3.438	9.28	6.62	1.178	0.900	22.51	4.02	13.27	5.90	1.416
	-	XXS	-	0.674	3.152	7.80	8.10	1.178	0.825	27.54	3.38	15.29	6.79	1.374
	-	-	-	0.800	2.900	6.602	9.294	1.178	0.759	31.613	2.864	16.6610	7.4050	1.3380
-	-	-	0.925	2.650	5.513	10.384	1.178	0.694	35.318	2.391	17.7130	7.8720	1.3060	
5 5.563	-	-	58	0.109	5.345	22.44	1.868	1.456	1.399	6.35	9.73	6.95	2.498	1.929
	-	-	108	0.134	5.295	22.02	2.285	1.456	1.386	7.77	9.53	8.43	3.03	1.920
	40	Std	408	0.258	5.047	20.01	4.30	1.456	1.321	14.62	8.66	15.17	5.45	1.878
	80	XS	SOS	0.375	4.813	18.19	6.11	1.456	1.260	20.78	7.89	20.68	7.43	1.839
	120	-	-	0.500	4.563	16.35	7.95	1.456	1.195	27.04	7.09	25.74	9.25	1.799
	160	-	-	0.625	4.313	14.61	9.70	1.456	1.129	32.96	6.33	30.0	10.80	1.760
	-	XXS	-	0.750	4.063	12.97	11.34	1.456	1.064	38.55	5.62	38.6	12.10	1.722
	-	-	-	0.875	3.813	11.413	12.880	1.456	0.998	43.810	4.951	36.6450	13.1750	1.6860
	-	-	-	1.000	3.563	9.966	14.328	1.456	0.933	47.734	4.232	39.1110	14.0610	1.6520

**PROPERTIES OF PIPE**

nominal pipe size <b>outside</b> diameter, in.	schedule number*			wall thickness, in.	inside diameter, in.	inside area, sq. in.	metal area, sq. in.	sq ft outside surface, per ft	sq ft inside surface, per ft	weight per ft, lbt	weight of water per ft, lb	moment of inertia, in. <sup>4</sup>	section modulus, in. <sup>3</sup>	radius gyration, in.
	a	b	c											
6 6.625	-	-	5S	0.109	6.407	32.2	2.231	1.734	1.677	5.37	13.98	11.85	3.58	2.304
	-	-	10S	0.134	6.357	31.7	2.733	1.734	1.664	9.29	13.74	14.40	4.35	2.295
	-	-	-	0.129	6.187	30.100	4.410	1.734	1.620	15.020	13.100	22.6600	6.8400	2.2700
	40	Std	40S	0.280	6.065	28.89	5.58	1.734	1.588	18.97	12.51	28.14	8.50	2.245
	80	XS	BOS	0.432	5.761	26.07	8.40	1.734	1.508	28.57	11.29	40.5	12.23	2.195
	120	-	-	0.562	5.501	23.77	10.70	1.734	1.440	36.39	10.30	49.6	14.98	2.153
	160	-	-	0.718	5.189	21.15	13.33	1.734	1.358	45.30	9.16	59.0	17.81	2.104
	-	XXS	-	0.864	4.897	18.83	15.64	1.734	1.282	53.16	8.17	66.3	20.03	2.060
	-	-	-	1.000	4.625	16.792	17.662	1.734	1.211	60.076	7.284	72.1190	21.7720	2.0200
	-	-	-	1.125	4.375	15.025	19.429	1.734	1.145	66.084	6.517	76.5970	23.1240	1.9850
8 8.625	-	-	5S	0.109	8.407	55.5	2.916	2.258	2.201	9.91	24.07	26.45	6.13	3.01
	-	-	10S	0.148	8.329	54.5	3.94	2.258	2.180	13.40	23.59	35.4	8.21	3.00
	-	-	-	0.219	8.187	52.630	5.800	2.258	2.150	19.640	22.900	51.3200	11.9000	2.9700
	20	-	-	0.250	8.125	51.8	6.58	2.258	2.127	22.36	22.48	57.7	13.39	2.962
	30	-	-	0.277	8.071	51.2	7.26	2.258	2.113	24.70	22.18	63.4	14.69	2.953
	40	Std	40S	0.322	7.981	50.0	8.40	2.258	2.089	28.55	21.69	72.5	16.81	2.938
	60	-	-	0.406	7.813	47.9	10.48	2.258	2.045	35.64	20.79	88.8	20.58	2.909
	80	XS	BOS	0.500	7.625	45.7	12.76	2.258	1.996	43.39	19.80	105.7	24.52	2.878
8 8.625	100	-	-	0.593	7.439	43.5	14.96	2.258	1.948	50.87	18.84	121.4	28.14	2.847
	120	-	-	0.718	7.189	40.6	17.84	2.258	1.882	60.63	17.60	140.6	32.6	2.807
	140	-	-	0.812	7.001	38.5	19.93	2.258	1.833	67.76	16.69	153.8	35.7	2.777
	160	-	-	0.906	6.813	36.5	21.97	2.258	1.784	74.69	15.80	165.9	38.5	2.748
	-	-	-	1.000	6.625	34.454	23.942	2.258	1.734	81.437	14.945	177.1320	41.0740	2.7190
	-	-	-	1.125	6.375	31.903	26.494	2.258	1.669	90.114	13.838	190.6210	44.2020	2.6810
	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10 10.750	-	-	5S	0.134	10.482	86.3	4.52	2.815	2.744	15.15	37.4	63.7	11.85	3.75
	-	-	10S	0.165	10.420	85.3	5.49	2.815	2.728	18.70	36.9	76.9	14.30	3.74
	-	-	-	0.219	10.312	83.52	7.24	2.815	2.70	24.63	36.2	100.46	18.69	3.72
	20	-	-	0.250	10.250	82.5	8.26	2.815	2.683	28.04	35.8	113.7	21.16	3.71
	30	-	-	0.307	10.136	80.7	10.07	2.815	2.654	34.24	35.0	137.5	25.57	3.69
	40	Std	40S	0.365	10.020	78.9	11.91	2.815	2.623	40.48	34.1	160.8	29.90	3.67
	60	XS	BOS	0.500	9.750	74.7	16.10	2.815	2.553	54.74	32.3	212.0	39.4	3.63
	80	-	-	0.593	9.564	71.8	18.92	2.815	2.504	64.33	31.1	244.9	45.6	3.60
	100	-	-	0.718	9.314	68.1	22.63	2.815	2.438	76.93	29.5	286.2	53.2	3.56
	120	-	-	0.843	9.064	64.5	26.24	2.815	2.373	89.20	28.0	324	60.3	3.52
	-	-	-	0.875	9.000	63.62	27.14	2.815	2.36	92.28	27.6	333.46	62.04	3.50
	140	-	-	1.000	8.750	60.1	30.6	2.815	2.291	104.13	26.1	368	68.4	3.47
	160	-	-	1.125	8.500	56.7	34.0	2.815	2.225	115.65	24.6	399	74.3	3.43
	-	-	-	1.250	8.250	53.45	37.31	2.815	2.16	126.82	23.2	428.17	79.66	3.39
	-	-	-	1.500	7.750	47.15	43.57	2.815	2.03	148.19	20.5	478.59	89.04	3.31
12 12.750	-	-	5S	0.156	12.438	121.4	6.17	3.34	3.26	20.99	52.7	122.2	19.20	4.45
	-	-	10S	0.180	12.390	120.6	7.11	3.34	3.24	24.20	52.2	140.5	22.03	4.44
	20	-	-	0.250	12.250	117.9	9.84	3.34	3.21	33.38	51.1	191.9	30.1	4.42
	30	-	-	0.330	12.090	114.8	12.88	3.34	3.17	43.77	49.7	248.5	39.0	4.39
	-	Std	40S	0.375	12.000	113.1	14.58	3.34	3.14	49.56	49.0	279.3	43.8	4.38
	40	-	-	0.406	11.938	111.9	15.74	3.34	3.13	53.53	48.5	300	47.1	4.37
	-	XS	BOS	0.500	11.750	108.4	19.24	3.34	3.08	65.42	47.0	362	56.7	4.33
	60	-	-	0.562	11.626	106.2	21.52	3.34	3.04	73.16	46.0	401	62.8	4.31
	80	-	-	0.687	11.376	101.6	26.04	3.34	2.978	88.51	44.0	475	74.5	4.27
	-	-	-	0.750	11.250	99.40	28.27	3.34	2.94	96.2	43.1	510.7	80.1	4.25
	100	-	-	0.843	11.064	96.1	31.5	3.34	2.897	107.20	41.6	562	88.1	4.22
	-	-	-	0.875	11.000	95.00	32.64	3.34	2.88	110.9	41.1	578.5	90.7	4.21
	120	-	-	1.000	10.750	90.8	36.9	3.34	2.814	125.49	39.3	642	100.7	4.17
	140	-	-	1.125	10.500	86.6	41.1	3.34	2.749	139.68	37.5	701	109.9	4.13
	-	-	-	1.250	10.250	82.50	45.16	3.34	2.68	153.6	35.8	755.5	118.5	4.09
	160	-	-	1.312	10.126	80.5	47.1	3.34	2.651	160.27	34.9	781	122.6	4.07

**PROPERTIES OF PIPE**

nominal pipe size outside diameter, in.	schedule number*			wall thickness, in.	inside diameter, in.	inside area, sq. in.	metal area, sq. in.	sq ft outside surface, per ft	sq ft inside surface, per ft	weight per ft, lbt	weight of water per ft, lb	moment of inertia, in. <sup>4</sup>	section modulus, in. <sup>3</sup>	radius gyration, in.
	a	b	c											
14 14,000	-	-	5S	0.156	13.688	147.20	6.78	3.67	3.58	23.0	63.7	162.6	23.2	4.90
	-	-	10S	0.188	13.624	145.80	8.16	3.67	3.57	27.7	63.1	194.6	27.8	4.88
	-	-	-	0.210	13.580	144.80	9.10	3.67	3.55	30.9	62.8	216.2	30.9	4.87
	-	-	-	0.219	13.562	144.50	9.48	3.67	3.55	32.2	62.6	225.1	32.2	4.87
	10	-	-	0.250	13.500	143.1	10.80	3.67	3.53	36.71	62.1	255.4	36.5	4.86
	-	-	-	0.281	13.438	141.80	12.11	3.67	3.52	41.2	61.5	285.2	40.7	4.85
	20	-	-	0.312	13.376	140.5	13.42	3.67	3.50	45.68	60.9	314	44.9	4.84
	-	-	-	0.344	13.312	139.20	14.76	3.67	3.48	50.2	60.3	344.3	49.2	4.83
	30	Std	-	0.375	13.250	137.9	16.05	3.67	3.47	54.57	59.7	373	53.3	4.82
	40	-	-	0.437	13.126	135.3	18.62	3.67	3.44	63.37	58.7	429	61.2	4.80
	-	-	-	0.469	13.062	134.00	19.94	3.67	3.42	67.8	58.0	456.8	65.3	4.79
	-	XS	-	0.500	13.000	132.7	21.21	3.67	3.40	72.09	57.5	484	69.1	4.78
	60	-	-	0.593	12.814	129.0	24.98	3.67	3.35	84.91	55.9	562	80.3	4.74
	-	-	-	0.625	12.750	127.7	26.26	3.67	3.34	89.28	55.3	589	84.1	4.73
	80	-	-	0.750	12.500	122.7	31.2	3.67	3.27	106.13	53.2	687	98.2	4.69
	100	-	-	0.937	12.126	115.5	38.5	3.67	3.17	130.73	50.0	825	117.8	4.63
120	-	-	1.093	11.814	109.6	44.3	3.67	3.09	150.67	47.5	930	132.8	4.58	
140	-	-	1.250	11.500	103.9	50.1	3.67	3.01	170.22	45.0	1028	146.8	4.53	
160	-	-	1.406	11.188	98.3	55.6	3.67	2.929	189.12	42.6	1117	159.6	4.48	
16 16,000	-	-	5S	0.165	15.670	192.90	8.21	4.19	4.10	28	83.5	257	32.2	5.60
	-	-	10S	0.188	15.624	191.70	9.34	4.19	4.09	32	83.0	292	36.5	5.59
	10	-	-	0.250	15.500	188.7	12.37	4.19	4.06	42.05	81.8	384	48.0	5.57
	20	-	-	0.312	15.376	185.7	15.38	4.19	4.03	52.36	80.5	473	59.2	5.55
	30	Std	-	0.375	15.250	182.6	18.41	4.19	3.99	62.58	79.1	562	70.3	5.53
	40	XS	-	0.500	15.000	176.7	24.35	4.19	3.93	82.77	76.5	732	91.5	5.48
	60	-	-	0.656	14.688	169.4	31.6	4.19	3.85	107.50	73.4	933	116.6	5.43
	80	-	-	0.843	14.314	160.9	40.1	4.19	3.75	136.46	69.7	1157	144.6	5.37
	100	-	-	1.031	13.938	152.6	48.5	4.19	3.65	164.83	66.1	1365	170.6	5.30
	120	-	-	1.218	13.564	144.5	56.6	4.19	3.55	192.29	62.6	1556	194.5	5.24
	140	-	-	1.437	13.126	135.3	65.7	4.19	3.44	223.64	58.6	1760	220.0	5.17
	160	-	-	1.593	12.814	129.0	72.1	4.19	3.35	245.11	55.9	1894	236.7	5.12
18 18,000	-	-	5S	0.165	17.670	245.20	9.24	4.71	4.63	31	106.2	368	40.8	6.31
	-	-	10S	0.188	17.624	243.90	10.52	4.71	4.61	36	105.7	417	46.4	6.30
	10	-	-	0.250	17.500	240.5	13.94	4.71	4.58	47.39	104.3	549	61.0	6.28
	20	-	-	0.312	17.376	237.1	17.34	4.71	4.55	59.03	102.8	678	75.5	6.25
	-	Std	-	0.375	17.250	233.7	20.76	4.71	4.52	70.59	101.2	807	89.6	6.23
	30	-	-	0.437	17.126	230.4	24.11	4.71	4.48	82.06	99.9	931	103.4	6.21
	-	XS	-	0.500	17.000	227.0	27.49	4.71	4.45	93.45	98.4	1053	117.0	6.19
	40	-	-	0.562	16.876	223.7	30.8	4.71	4.42	104.75	97.0	1172	130.2	6.17
	60	-	-	0.750	16.500	213.8	40.6	4.71	4.32	138.17	92.7	1515	168.3	6.10
	80	-	-	0.937	16.126	204.2	50.2	4.71	4.22	170.75	88.5	1834	203.8	6.04
	100	-	-	1.156	15.688	193.3	61.2	4.71	4.11	207.96	83.7	2180	242.2	5.97
	120	-	-	1.375	15.250	182.6	71.8	4.71	3.99	244.14	79.2	2499	277.6	5.90
140	-	-	1.562	14.876	173.8	80.7	4.71	3.89	274.23	75.3	2750	306	5.84	
160	-	-	1.781	14.438	163.7	90.7	4.71	3.78	308.51	71.0	3020	336	5.77	
20 20,000	-	-	5S	0.188	19.634	302.40	11.70	5.24	5.14	40	131.0	574	57.4	7.00
	-	-	10S	0.218	19.564	300.60	13.55	5.24	5.12	46	130.2	663	66.3	6.99
	10	-	-	0.250	19.500	298.60	15.51	5.24	5.11	52.73	129.5	757	75.7	6.98
	20	Std	-	0.375	19.250	291.0	23.12	5.24	5.04	78.60	126.0	1114	111.4	6.94
	30	XS	-	0.500	19.000	283.5	30.6	5.24	4.97	104.13	122.8	1457	145.7	6.90
	40	-	-	0.593	18.814	278.0	36.2	5.24	4.93	122.91	120.4	1704	170.4	6.86
	60	-	-	0.812	18.376	265.2	48.9	5.24	4.81	166.40	115.0	2257	225.7	6.79
	-	-	-	0.875	18.250	261.6	52.6	5.24	4.78	178.73	113.4	2409	240.9	6.77
	80	-	-	1.031	17.938	252.7	61.4	5.24	4.70	208.87	109.4	2772	277.2	6.72
	100	-	-	1.281	17.438	238.8	75.3	5.24	4.57	256.10	103.4	3320	332	6.63



## ABOUT US

**Inveno Engineering LLC.** personnel are experts in the field of steam and condensate systems engineering with vast real-world experience and highly recognized professionals in the industrial arena. Our services include design, engineering, requests for quotations, standard operating procedures, root cause analysis, system optimization, steam balancing and project management. **Inveno Engineering LLC.** can review your entire steam and condensate system from steam generation to distribution to end user processes and condensate recovery.