


# Energy Tips



Steam



Motors



Compressed Air

## Automatic Blowdown Control Systems

These systems optimize surface blowdown by regulating water volume discharged in relation to amount of dissolved solids present. Conductivity, TDS, silica or chlorides concentrations, and/or alkalinity are reliable indicators of salts and other contaminants dissolved in boiler water. A probe provides feedback to a controller driving a modulating blowdown valve. An alternative is proportional control—with blowdown rate set proportional to makeup water flow.

## Cycles of Concentration

“Cycles of concentration” refers to the accumulation of impurities in the boiler water. If the boiler water contains ten times the level of impurities in the makeup water, it is said to have ten cycles of concentration.

## References and Footnotes

1. “Consensus Operating Practices for Control of Feedwater/Boiler Water Chemistry in Modern Industrial Boilers”, published by the ASME, 1994.
2. “Recommended Rules for the Care and Operation of Heating Boilers”, Section VI of the ASME Boiler and Pressure Vessel Code, 1995.
3. “Recommended Guidelines for the Care of Power Boilers”, Section VII of the ASME Boiler and Pressure Vessel Code, 1995.

*Adapted from an EnergyTIPS fact sheet that was originally published by the Industrial Energy Extension Service of Georgia Tech. For additional information on industrial energy efficiency measures, contact the OIT Clearinghouse at (800) 862-2086.*



## Minimize Boiler Blowdown

Minimizing your blowdown rate can substantially reduce energy losses, as the temperature of the blown-down liquid is the same as that of the steam generated in the boiler. Minimizing blowdown will also reduce makeup water and chemical treatment costs.

As water evaporates in the boiler steam drum, solids present in the feedwater are left behind. The suspended solids form sludge or sediments in the boiler, which degrades heat transfer. Dissolved solids promote foaming and carryover of boiler water into the steam. To reduce the levels of suspended and total dissolved solids (TDS) to acceptable limits, water is periodically discharged or blown down from the boiler. Mud or bottom blowdown is usually a manual procedure done for a few seconds on intervals of several hours. It is designed to remove suspended solids that settle out of the boiler water and form a heavy sludge. Surface or skimming blowdown is designed to remove the dissolved solids that concentrate near the liquid surface. Surface blowdown is often a continuous process.

Insufficient blowdown may lead to carryover of boiler water into the steam, or the formation of deposits. Excessive blowdown will waste energy, water, and chemicals. The optimum blowdown rate is determined by various factors including the boiler type, operating pressure, water treatment, and quality of makeup water. Blowdown rates typically range from 4% to 8% of boiler feedwater, but can be as high as 10% when makeup water has a high solids content.

## Example

Assume that the installation of an automatic blowdown control system (see sidebar) reduces your blowdown rate from 8% to 6%. This example assumes a continuously operating natural-gas-fired, 150-psig, 100,000-pound-per-hour steam boiler. Assume a makeup water temperature of 60°F, boiler efficiency of 82%, with fuel valued at \$3.00 per million Btu (MBtu), and the total water, sewage and treatment costs at \$0.004 per gallon. Calculate the total annual cost savings.

$$\text{Boiler Feedwater: Initial} = \frac{100,000}{(1 - 0.08)} = 108,695 \text{ lbs/hr}$$

$$\text{Final} = \frac{100,000}{(1 - 0.06)} = 106,383 \text{ lbs/hr}$$

$$\text{Makeup Water Savings} = 108,695 - 106,383 = 2312 \text{ lbs/hr}$$

$$\text{Enthalpy of boiler water} = 338.5 \text{ Btu/lb; for makeup water at } 60^\circ\text{F} = 28 \text{ Btu/lb}$$

$$\text{Thermal Energy Savings} = 338.5 - 28 = 310.5 \text{ Btu/lb}$$

$$\text{Annual Fuel Savings} = \frac{2312 \text{ lbs/hr} \times 8760 \text{ hrs/yr} \times 310.5 \text{ Btu/lb} \times \$3.00/\text{MBtu}}{0.82 \times 10^6} = \$23,007$$

$$\text{Annual Water and Chemical Savings} = \frac{2312 \text{ lbs/hr} \times 8760 \text{ hrs/yr} \times \$0.004/\text{gal}}{8.34 \text{ lbs/gal}} = \$9,714$$

$$\text{Annual Cost Savings} = \$23,007 + \$9,714 = \$32,721$$

## Suggested Actions

Review your blowdown practices to identify energy saving opportunities. Examine operating practices for boiler feedwater and blowdown rates developed by the American Society of Mechanical Engineers (ASME). Considerations include operating pressure, steam purity, and deposition control. Consider an automatic blowdown control system (see sidebar).

# About DOE's Office of Industrial Technologies

The Office of Industrial Technologies (OIT), through partnerships with industry, government, and non-governmental organizations, develops and delivers advanced energy efficiency, renewable energy, and pollution prevention technologies for industrial applications. OIT is part of the U.S. Department of Energy's Office of Energy Efficiency and Renewable Energy.

OIT encourages industry-wide efforts to boost resource productivity through a strategy called Industries of the Future (IOF). IOF focuses on the following nine energy and resource intensive industries:

Agriculture	Chemicals	Glass	Mining	Steel
Aluminum	Forest Products	Metal Casting	Petroleum	

To help industries begin to save energy, reduce costs, and cut pollution right away, OIT offers a comprehensive portfolio of emerging technology, practices, tools, information, and resources in a variety of application areas, such as motor systems, steam systems, compressed air systems, and combined heat and power systems. Likewise, OIT's Industrial Assessment Centers (IAC), located throughout the U.S., offer energy, waste, and productivity assessments to small and medium-sized manufacturers. Users can take advantage of the abundant resources, such as software, fact sheets, training materials, etc. available from OIT.

**Motor Systems** — helps industry increase productivity and reliability through energy-efficient electric motor-driven systems.

#### Documents -

- Buying an Energy-Efficient Electric Motor
- Optimizing Your Motor-Driven System
- Frequently Asked Questions on: The Impacts of the Energy Policy Act of 1992 on Industrial End Users of Electric Motor-Driven Systems
- Energy Management for Motor Driven Systems
- Improving Pumping System Performance: A Sourcebook for Industry

#### Software -

- MotorMaster+ 3.0 and training CD
- ASDMaster
- Pumping System Assessment Tool

#### Training -

- MotorMaster+ 3.0 Software
- Adjustable Speed Drive Application
- Pumping System Optimization
- Pumping System Assessment Tool

Access the Web site at [www.motor.doe.gov](http://www.motor.doe.gov).

**Steam Systems** — helps industry enhance productivity, increase profits, and reduce emissions through better steam system management.

#### Documents -

- Energy Efficiency Handbook
- Plant Services Article - *The Steam Challenge*
- Energy Manager Article - *Steaming Ahead*
- Oak Ridge National Laboratory's Insulation Guidelines
- 1998 IETC Steam Session Papers

#### Case Studies -

- Georgia Pacific Achieves 6-Month Payback
- Bethlehem Steel Showcase Demonstration

#### Software -

- 3EPlus Software for Determining Optimal Insulation Thickness

Access the Web site at [www.oit.doe.gov/steam](http://www.oit.doe.gov/steam).

**Compressed Air Systems** — dedicated to improving the efficiency and performance of industrial compressed air systems.

#### Documents -

- Improving Compressed Air System Performance: A Sourcebook for Industry

#### Training -

- Fundamentals of Compressed Air Systems  
(For schedule and location, call (800) 862-2086)

Access the Web site at [www.knowpressure.org](http://www.knowpressure.org).

**Industrial Assessment Centers** — enable small and medium-sized manufacturers to have comprehensive industrial assessments performed at no cost to the manufacturer.

#### Documents -

- IAC Database

Access the Web site at [www.oit.doe.gov/iac](http://www.oit.doe.gov/iac).

**For more information, simply check the box next to the product, fill out the form below and fax back to (360) 586-8303:**

Name: \_\_\_\_\_ Title: \_\_\_\_\_

Organization: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_ E-mail: \_\_\_\_\_

Comments: \_\_\_\_\_

For more information on Motor, Steam, Compressed Air Systems, and IACs, call the OIT Clearinghouse at (800) 862-2086, or access the Web site at [www.oit.doe.gov](http://www.oit.doe.gov).